

Plastic & Foam Construction Materials

(PFCM) Work Permit Application

Important Information

To be used when installing, repairing or making penetrations through any plastic building materials. This covers, but is not limited to, Expanded Polystyrene or any other foam panels, spray on foam insulation, PVC panels etc.

This Permit is to be read in conjunction with Chubb PFCM Work Permit Instructions. Precautions indicated must be adhered to without exception.

Section 1 - General Details

Building:		Area/Department:	
Equipment to be Used:			
Description of Work:			

Personnel Involved:

Section 2 - Authorization (Manager, Supervisor or Authorized Individual)

Permit begins:		Time:	
Permit expires:		Time:	
Authorized By:		Position:	
Signature of Employee:			
Date:		Time:	

Section 3 - Work Acceptance (Individual responsible for completing the work)

I have been briefed and I understand the work to be performed. I am fully aware of the safety precautions and agree to abide by these precautions.

Accepted By:	
--------------	--

Section 4 - Standard Precautions (Check each item carefully)

- Where installed, the Fire Sprinkler System is to be fully operable and in service.
- Those doing the work are trained and competent in the works covered by this Permit and in the use of fire fighting equipment and company emergency procedures.
- Penetrations through the panel should be avoided where possible but where necessary all cables and services which pass through should be contained within a non-combustible housing and opening sealed with fire stopping. Particular care is necessary to ensure cables are not exposed to damage through contact with metal facings at cable entry points.
- Only slow speed drilling/cutting methods (manual preferably) are to be used. Powered cutting or drilling is not to be permitted unless precautions to minimize hot cuttings and swarf (e.g. slow speed) are in place. These are to be outlined under Special Precautions below.
- Welding or grinding or other hot work is not to be undertaken at any time on PFCM.
- All tools and equipment are checked & in good condition. All blades and cutting surfaces must be properly sharpened and of correct material for task to be undertaken.
- The work area is checked and is free of combustible and flammable materials.
- A Fire Extinguisher and/or Hose Reel is always available at the PFCM work area.
- The Department Manager or Supervisor is notified of the intent to work.
- No exposed foam cores or easily ignited faces are left exposed at end of work day.

Section 5 - Special Precautions (List any additional requirements necessary prior to work commencement)

Section 6 - Final Inspection (Manager, Supervisor, or Authorized Individual)

I certify that I have checked the area at the completion of the work. All penetrations were found to be sealed & no exposed foam core or other hazardous conditions were noted. All cuttings, swarf and other waste have been removed.

- All penetrations are sealed and no internal core is left exposed.
- Waste material has been removed and disposed of safely outside the building.

Inspected By:		Position:	
Signed:			
Date:		Time:	

About Chubb in Taiwan

Chubb is the world's largest publicly traded property and casualty insurer. Chubb, via acquisitions by its predecessor companies, has been present in Taiwan for over 20 years. Its operation in Taiwan (Insurance Company of North America, Taiwan Branch) provides specialized and customized coverages include Marine, Property, Liability, Energy, Professional Indemnity, Directors & Officers, Financial Lines, Utilities as well as Accident & Health, for a broad client base, including many of the country's largest companies.

More information can be found at www.chubb.com/tw

Contact Us

Insurance Company of North America, Taiwan Branch, a member of Chubb Group

Grosvenor Place
Level 10, 8 Hsin Yi Road, Sec. 5
Taipei 110, Taiwan
O +886 2 8758 1800
F +886 2 8758 1888
www.chubb.com/tw

Chubb. Insured.SM