

Checklist for Shutdowns

Facility/Area: _____ Date: _____

Category	Yes	No	Comments
Have a Plan			
<input type="checkbox"/> Establish or review the emergency action plan to consider actions after the exit of non-essential occupants.			
<input type="checkbox"/> Designate an Emergency Coordinator and Emergency Action Team.			
<input type="checkbox"/> Schedule meetings and drills to ensure essential onsite staff knows roles and responsibilities.			
<input type="checkbox"/> Detail communication procedures for employees, suppliers, vendors, contractors, and clients.			
Building Systems and Maintenance			
<input type="checkbox"/> Understand critical ongoing facility utility needs; particularly energy, fire protection, heating, and plumbing.			
<input type="checkbox"/> Be proactive in performing preventative maintenance on back up resources such as emergency generators, and fire pumps.			
<input type="checkbox"/> Plan for unavailable contractors and third-party maintenance vendors.			
<input type="checkbox"/> Prioritize considerations for conducting in-house inspection, testing, and maintenance as allowed by local regulations on critical building systems.			
<input type="checkbox"/> Cross train employees that would remain onsite, so that they know what inspections, testing, and maintenance they are qualified to accommodate.			
<input type="checkbox"/> Establish shut down and isolation procedures for critical equipment, utilities, and entire facility.			
<input type="checkbox"/> Properly shut down any nonessential equipment or systems (electric, water, gas) as appropriate.			
<input type="checkbox"/> Gas should be isolated (unless essential for maintaining heating).			
<input type="checkbox"/> Maintain heat to ensure there is no possibility of freezing.			
<input type="checkbox"/> Fire sprinkler systems, fire detection systems, fire alarms, and fire pumps are maintained and remain operational.			
<input type="checkbox"/> Proper machinery start up procedures are required to recommission the facility.			
Building Fire & Security			
<input type="checkbox"/> Plan for additional security guards, roving tours, and fire watches.			
<input type="checkbox"/> Notify local authorities including police and fire service when a building becomes unoccupied.			
<input type="checkbox"/> Make sure existing facility security systems are well maintained, and in good working order, including alarm transmission.			
<input type="checkbox"/> Remove external combustible material (including trash bins, etc.) from nearby the building.			
<input type="checkbox"/> Ensure there is available back up personnel (a minimum of two) for any proprietary or remote monitoring stations responsible for fire and security alarms.			

Category	Yes	No	Comments
Building Fire & Security			
<input type="checkbox"/> Make sure sprinkler valves are normally in the secured, open position, and that gauges are reading normal pressures.			
<input type="checkbox"/> Make sure fire pump controllers, fire alarm panels and detection devices are in normal energized condition, with no trouble alarms.			
<input type="checkbox"/> Report any fire protection system (sprinkler systems, fire detection systems, special extinguishing systems) impairments to your local fire service, central monitoring station, and to your insurance carrier.			
<input type="checkbox"/> Train essential staff now on roles and responsibilities in reporting any fire protection impairments. For Chubb clients, report impairments at www.chubb.com/impairment .			
<input type="checkbox"/> For buildings lacking active fire detection or sprinkler systems, consider implementing a 24-hour fire watch.			
<input type="checkbox"/> Consider conducting hourly fire watch rounds when the building is unoccupied. Rounds should be recorded and should cover all key areas.			
<input type="checkbox"/> Ensure the fire watch has reliable means of communication and are instructed to call the fire department upon discovery of fire.			
<input type="checkbox"/> Ensure all handheld fire extinguishers and standpipe hose connections are in good working order now, in accordance with local regulations.			
<input type="checkbox"/> If Hot Work is conducted, be sure to follow the Chubb Hot Work Permit Program and Procedures.			
Building Water & Freezing			
<input type="checkbox"/> Shut off water in any areas of the building where it is not needed to help prevent interior water damage.			
<input type="checkbox"/> Drain domestic plumbing pipes and add anti-freeze to any areas where water might remain if subject to freezing conditions.			
<input type="checkbox"/> Guards and other remaining staff should be trained on critical valve shut off locations and water damage mitigation efforts in the event of pipe burst, leakage event, etc.			
<input type="checkbox"/> Ensure the building maintains reliable heat to maintain a minimum temperature of 40°F (4°C).			
<input type="checkbox"/> For areas protected by a wet pipe sprinkler system, maintain adequate heat to prevent freezing of sprinkler pipes.			
<input type="checkbox"/> Consider installing IoT (Internet of Things) enabled water leak detection and temperature sensors in key critical areas of the building.			
<input type="checkbox"/> Make sure the building remains weather (wind, water, and cold air) tight.			
<input type="checkbox"/> Inspect roofs and flashing to ensure they are secured properly.			
<input type="checkbox"/> Clear clogged roof drains, rain gutters and downspouts. Check drain pumps and downspouts.			
<input type="checkbox"/> Plan for cold weather as appropriate. Implement a program for snow removal for emergency access and roof loading to the building.			
<input type="checkbox"/> Ensure all doors, windows, skylights, vents and shafts are weather tight to prevent freezing.			

Category	Yes	No	Comments
Building Water & Freezing			
<input type="checkbox"/> Inspect emergency heating systems now to assure proper operation and ensure adequate fuel supplies and reserves.			
<input type="checkbox"/> Operational jurisdictional objects such as boilers, water heaters, air tanks and pressure vessels must be maintained, inspected and operated according to local law.			
<input type="checkbox"/> Jurisdictional objects not in operation should be isolated from all energy sources and locked and tagged out to prevent unintended use.			

Completed by: _____ Date: _____

Reviewed by: _____ Date: _____

Chubb. Insured.SM

Chubb is the marketing name used to refer to subsidiaries of Chubb Limited providing insurance and related services. For a list of these subsidiaries, please visit our website at www.chubb.com. Insurance provided by ACE American Insurance Company and its U.S. based Chubb underwriting company affiliates. This document is advisory in nature and is offered as a resource to be used together with your professional insurance advisors in maintaining a loss prevention program. No liabilities or warranties are assumed or provided by the information contained in this document.

Form 09-01-0192 (Rev. 4/20)